



**CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES**

**16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979**

**Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.**

e-mail: rrisley@water-treat-tech.com

FACILITY : **VILLAGE OF NEW MINDEN**

DATE : **July 25, 2018**

REPORTING MONTH : **July 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office.
Do not send this sheet to IEPA. See IEPA reporting information below.

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H	NH3-N (PPM)	D. O. (PPM)	F.Coliform N/100 ml.
07/05/18	INF	116.3	23.6	7.17	52.1	—	—
07/28/18	EFF (N/S)	11.7	6	7.51	24	6.82	10
							(May-Oct)
3 days	WWTF check						
NOTE:							

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.
Comments:

NEW MINDEN

(* CBOD 5 if applicable)