



**CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES**

**16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979**

**Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.**

**e-mail: rrisley@water-treat-tech.com**

**FACILITY : RACCOON SCHOOL  
DATE : JANUARY 28, 2018  
REPORTING MONTH : JANUARY 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA.

DATE / TIME	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	Fecal Coliform (N/100 ml.)
1/19/18@830am	INFLUENT	243	69.2	—	—	—	—
“ @830am	EFFLUENT	5.6	4	7.16	3.31	(JG)	
( By: JG )							(May-Oct)

If there are any questions, please advise.

( \* CBOD 5 if applicable )

**(Raccoon School)**

Comments:

Director

Robert Risley — Lab