



Water Treat Technology

Certified Wastewater
Contract Operator
Consulting Services

16 Greve Drive, Centralia, IL 62801
Phone: (618) 923-0520 Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Robert Risley, IEPA Class 1
Wastewater Treatment Operator
Industrial Engineer B.S.

PERMIT NUMBER: MO-0096644
CLIENT: Tamarac Estates Wastewater Treatment Facility
SAMPLE: Effluent - out fall # 001
DATE: 6/10/2019
REPORTING MONTH: 2nd Qtr

Sample Date	Analysis	Result	Limit	Units	Method
06/07/19	TSS	14.4	30	mg/L	SM-254 D-97

The analysis of wastewater is conducted in accordance with US EPA approved methods listed in 40CFR Part 136. All results expressed on an as received basis unless indicated by a footnote.

These are the test results for your wastewater facility. You will want to keep these on file.

If you have any questions, please advise.

Natalie Frazier
Lab Director