



CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES

16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979

Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.

e-mail: rrisley@water-treat-tech.com

FACILITY : **VILLAGE OF TAMAROA**  
DATE : **APRIL 28, 2018**  
REPORTING MONTH : **APRIL 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	Fecal Coli. (N/100ml)
4/7/18	INF	48	54.8	—	—	—	—
“	EFF	21	30	8.29	0.456	5.21	—
							(May—Oct)
<b>Treasurer:</b>							

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC**

If there are any questions, please advise.  
Comments:

(V. TAM.)

(\* CBOD 5 if applicable )