



# Water Treat Technology

Robert Risley, IEPA Class 1 Certified  
Wastewater Treatment Operator  
& Industrial Engineer B.S.

16 Greve Drive, Centralia, IL 62801  
Phone: (618) 923-0520 Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Contract Operator  
&  
Consulting Services

FACILITY: FIELD SCHOOL

DATE: 10/25/2018

REPORTING MONTH: October 2018

**Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE     | SAMPLE | * BOD5 (ppm) | TSS (ppm) | pH   | NH <sub>3</sub> -N (ppm) | DO (ppm) | Fecal Coli (N/100mL) |
|----------|--------|--------------|-----------|------|--------------------------|----------|----------------------|
| 10/06/18 | INF    | 81.70        | 227.50    | ---  | ---                      | ---      | ---                  |
| 10/06/18 | EFF    | 5.70         | 6.00      | 7.86 | 0.29                     | 5.02     | 0                    |
|          |        |              |           |      |                          |          | (May - Oct)          |
|          |        |              |           |      |                          |          |                      |
|          |        |              |           |      |                          |          |                      |
| SUPT:    |        |              |           |      |                          |          |                      |

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.**

If you have any questions, please advise.

Robert Risley  
Lab Director

\* CBOD 5 if applicable