



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

e-mail: rrisley@water-treat-tech.com

FACILITY : **VILLAGE OF HUEY**
DATE : **FEBRUARY 28, 2018**
REPORTING MONTH : **FEBRUARY 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. **Do not send this sheet to IEPA. These results should be kept on file at your office. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	F.Coliform (N/100ml)
2/14/18	Influent	45.8	13	7.9	26.9	—	—
“	Effluent	1.9	1.2	7.6	0.289	10.42	
							(May—Oct)
3 days	Plant check						
BRIAN:							

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise. (HUEY) (* CBOD 5 if applicable)

Comments: