



**CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES**

**16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979**

e-mail: rrisley@water-treat-tech.com

**Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.**

**FACILITY : VILLAGE OF HUEY
DATE : MARCH 28, 2018
REPORTING MONTH : MARCH 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. **Do not send this sheet to IEPA. These results should be kept on file at your office. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	F.Coliform (N/100ml)
3/14/18	Influent	35	55	7.8	8.95	—	—
“	Effluent	2.7	0.4	7.4	0.125	9.47	
							(May—Oct)
3 days	Plant check						
BRIAN:							

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.

(HUEY)

(* CBOD 5 if applicable)

Comments: