



CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES

16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.

FACILITY : IRVINGTON SANITARY DISTRICT

DATE : May 28, 2018

REPORTING MONTH : May 2018

DEAR SIR :

Below is a summary of test results on your wastewater facility.

**These results should be kept on file at your office. Do not send this sheet to IEPA.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	Fecal Coli. (N/100ml)
5/19/18 @1130am	INFLUENT	55.6	73	—	—	—	—
“	EFFLUENT	5.9	21	8.08	1.55	(JG)	300
							(May-Oct)

If there are any questions, please advise.

( \* CBOD 5 if applicable )

(Irv. San. Dist.)

Comments:

Robert Risley — Lab Director