



**CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES**

**16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com**

**Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.**

**FACILITY : VILLAGE OF JUNCTION CITY  
DATE : July 25, 2018  
REPORTING MONTH : July 2018**

**DEAR SIR :**

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA.

<b>DATE / TIME</b>	<b>SAMPLE POINT</b>	<b>* BOD 5 (PPM)</b>	<b>S. S. (PPM)</b>	<b>p H (UNITS)</b>	<b>NH3-N (PPM)</b>	<b>D. O. (PPM)</b>	<b>Fecal Coli. (N/100ml)</b>
07/11/18	INFLUENT	254.8	96.4	—	—	—	—
“	EFFLUENT	9.6	18.3	7.42	0.090	(JG)	0
							(May-Oct)
Sampled by:							
JG							

If there are any questions, please advise.

( \* CBOD 5 if applicable)

**(V. Junction City)**

Comments:

Robert Risley — Lab Director