



**CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES**

**16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com**

**Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.**

**FACILITY : VILLAGE OF NEW MINDEN  
DATE : May 28, 2018  
REPORTING MONTH : May 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office.  
**Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE         | SAMPLE POINT | * BOD 5 (PPM) | S. S. (PPM) | p H  | NH3-N (PPM) | D. O. (PPM) | F.Coliform N/100 ml. |
|--------------|--------------|---------------|-------------|------|-------------|-------------|----------------------|
| 5/22/18      | INF          | 164           | 20.4        | 7.31 | 51.1        | —           | —                    |
| “            | EFF (N/S)    | 16.7          | 7.3         | 7.52 | 27          | 8.64        |                      |
|              |              |               |             |      |             |             |                      |
|              |              |               |             |      |             |             | (May-Oct)            |
|              |              |               |             |      |             |             |                      |
|              |              |               |             |      |             |             |                      |
| 3 days       | WWTF check   |               |             |      |             |             |                      |
| <b>NOTE:</b> |              |               |             |      |             |             |                      |

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC**

If there are any questions, please advise.  
Comments:

**NEW MINDEN**

( \* CBOD 5 if applicable)