



# Water Treat Technology

Robert Risley, IEPA Class 1 Certified  
Wastewater Treatment Operator  
& Industrial Engineer B.S.

16 Greve Drive, Centralia, IL 62801  
Phone: (618) 923-0520 Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Contract Operator  
&  
Consulting Services

FACILITY: VILLAGE OF ODIN

DATE: 11/21/2018

REPORTING MONTH: November 2018

**Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE                    | SAMPLE | * BOD5 (ppm) | TSS (ppm) | pH   | NH <sub>3</sub> -N (ppm) | DO (ppm) | Fecal Coli (N/100mL) |
|-------------------------|--------|--------------|-----------|------|--------------------------|----------|----------------------|
| 11/20/18                | INF    | 59.30        | 34.80     | 0.00 | ---                      | ---      | ---                  |
| 11/20/18                | EFF    | 4.40         | 8.00      | 7.65 | 8.24                     | 5.92     | -                    |
|                         |        |              |           |      |                          |          | (May - Oct)          |
|                         |        |              |           |      |                          |          |                      |
|                         |        |              |           |      |                          |          |                      |
| SAMPLED BY: JASON GREEN |        |              |           |      |                          |          |                      |

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.**

If you have any questions, please advise.

Robert Risley  
Lab Director

\* CBOD 5 if applicable