



**CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES**

**16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com**

**Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.**

FACILITY : **VILLAGE OF ODIN**  
DATE : **June 28, 2018**  
REPORTING MONTH : **June 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA.

DATE / TIME	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	Fecal Coli. (N/100ml)
6/19/18@ 930am	INFLUENT	66.7	98	7.40	—	—	—
“ @ 1045am	EFFLUENT	5.0	6	7.68	4.90	(JG)	100
							(May-Oct)
Sampled by:							
JG							

If there are any questions, please advise.

( \* CBOD 5 if applicable)

**(V. Junction City)**

Comments:

Robert Risley — Lab Director