



Water Treat Technology

Robert Risley, IEPA Class 1 Certified
Wastewater Treatment Operator
& Industrial Engineer B.S.

16 Greve Drive, Centralia, IL 62801
Phone: (618) 923-0520 Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Contract Operator
&
Consulting Services

FACILITY: VILLAGE OF ODIN

DATE: 2/20/2019

REPORTING MONTH: February 2019

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.

DATE	SAMPLE	* BOD5 (ppm)	TSS (ppm)	pH	NH ₃ -N (ppm)	DO (ppm)	Fecal Coli (N/100mL)
02/14/19	INF	34.40	115.60	0.00	---	---	---
02/14/19	EFF	6.20	6.00	7.64	7.14	10.81	-
							(May - Oct)
SAMPLED BY: JASON GREEN							

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.

If you have any questions, please advise.

Robert Risley
Lab Director

* CBOD 5 if applicable