



CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES

16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.

FACILITY : **VILLAGE OF PATOKA**  
DATE : **JANUARY 28, 2018**  
REPORTING MONTH : **JANUARY 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. **These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D.O. (PPM)	F.Coliform N/100 ml.
1/14/18	INFLUENT	151	77	—	—	—	—
“	EFFLUENT	NO	FLOW				
							(May—Oct)
<b>NOTE :</b>							

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC**

If there are any questions, please advise.  
Comments:

**V. Patoka**

( \* CBOD 5 if applicble)