



# Water Treat Technology

Robert Risley, IEPA Class 1 Certified  
Wastewater Treatment Operator  
& Industrial Engineer B.S.

16 Greve Drive, Centralia, IL 62801  
Phone: (618) 923-0520 Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Contract Operator  
&  
Consulting Services

FACILITY: VILLAGE OF PATOKA

DATE: 7/1/2019

REPORTING MONTH: July 2019

**Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE     | SAMPLE | * BOD5 (ppm) | TSS (ppm) | pH   | NH <sub>3</sub> -N (ppm) | DO (ppm) | Fecal Coli (N/100mL) | CL <sub>2</sub> Resid. (ppm) |
|----------|--------|--------------|-----------|------|--------------------------|----------|----------------------|------------------------------|
| 07/01/19 | INF    | 26.40        | 19.50     | ---  | ---                      | ---      | ---                  | ---                          |
| 07/01/19 | EFF    | 22.00        | 43.00     | 7.91 | 0.051                    | 5.75     | 1,000                |                              |
|          |        |              |           |      |                          |          | (May - Oct)          | (May - Oct)                  |
|          |        |              |           |      |                          |          |                      |                              |
|          |        |              |           |      |                          |          |                      |                              |
| NOTE:    |        |              |           |      |                          |          |                      |                              |

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.**

If you have any questions, please advise.

Natalie Frazier  
Lab Director

\* CBOD 5 if applicable