



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

e-mail: rrisley@water-treat-tech.com

FACILITY : **VILLAGE OF RICHVIEW**
DATE : **FEBRUARY 28, 2018**
REPORTING MONTH : **FEBRUARY 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (Units)	D.O. (ppm)	F.Coliform (N/100 ml)	T. Phos. (PPM)	NH3-N (PPM)
2/04/18	INFLUENT	179	246	—	—	—	—	—
“	EFFLUENT	6.0	6.0	8.1	8.37		4.52	5.97
						(May—Oct)		
3 days	WWTF check							
NOTE :								

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.
Comments:

(V. Richview WWTP)

(* CBOD 5 if applicable)