



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

FACILITY : **ROLLING MEADOWS MHC**
DATE : **APRIL 28, 2018**
REPORTING MONTH : **APRIL 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE | SAMPLE POINT | * BOD 5 (PPM) | S. S. (PPM) | p H (UNITS) | NH3-N (PPM) | D. O. (PPM) | Fecal Coliform (N/100 ml.) |
|--------|--------------|---------------|-------------|-------------|-------------|-------------|----------------------------|
| 4/8/18 | INFLUENT | 80 | 88 | — | — | — | — |
| “ | EFFLUENT | 1.83 | 4.7 | 7.93 | 12.7 | 9.93 | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.
Comments:

(Roll. Meadows)

(* CBOD 5 if applicable)