



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

e-mail: rrisley@water-treat-tech.com

FACILITY : **SPRING GARDEN CCSD#178 (Dodds)**
DATE : **JANUARY 28, 2018**
REPORTING MONTH : **JANUARY 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D.O. (PPM)	Fecal Coliform (N/100 ml.)
1/20/18	INFLUENT			—	—	—	—
“	EFFLUENT	NO	FLOW				
							(May—Oct)
SUPT:							

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

(Spring Garden CCSD)

(* CBOD 5 if applicable)