



# Water Treat Technology

Certified Wastewater  
Contract Operator  
Consulting Services

16 Greve Drive, Centralia, IL 62801  
Phone: (618) 923-0520 Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Robert Risley, IEPA Class 1  
Wastewater Treatment Operator  
Industrial Engineer B.S.

PERMIT NUMBER: MO-0132004  
CLIENT: Oak Creek Estates Wastewater Treatment Facility  
SAMPLE: Effluent  
DATE: 3/1/2018  
REPORTING MONTH: January 2018

Method	Analysis	Result	Limit	Units	Sample Date	Analysis Date
SM-5210 B-01	B.O.D. (5-Day)	3.500	30.000	mg/L	01/30/18	01/30/18
SM-254 D-97	TSS	7.000	30.000	mg/L	01/30/18	01/30/18
8156	pH	7.300	0.000	S.U.	01/30/18	01/30/18
10205	NH <sub>3</sub>	0.765	0.000	mg/L	01/30/18	01/30/18
SM-4500-0 G-01	D.O.	0.250	0.000	mg/L	01/30/18	01/30/18
8167	CL <sub>2</sub>	0.000	0.000	mg/L	01/30/18	01/30/18

\*\*\* The analysis of wastewater is conducted in accordance with US EPA approved methods listed in 40CFR Part 136. All results expressed on an as received basis unless indicated by a footnote. \*\*\*

\*\* These are the test results for your wastewater facility. You will want to keep these on file. \*\*

If you have any questions, please advise.

Robert Risley  
Lab Director