



# Water Treat Technology

Certified Wastewater  
Contract Operator  
Consulting Services

16 Greve Drive, Centralia, IL 62801  
Phone: (618) 923-0520 Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Robert Risley, IEPA Class 1  
Wastewater Treatment Operator  
Industrial Engineer B.S.

PERMIT NUMBER: MO-0132004

CLIENT: Oak Creek Estates Wastewater Treatment Facility

SAMPLE: Inf/Eff - Percent Removal

DATE: 4/10/2019

REPORTING MONTH: 1st Qtr

SAMPLE DATE: 3/19/2019

B.O.D. (5-Day)	Result	Units	Method
Influent	226.9	mg/L	SM-5210 B-01
Effluent	8.3	mg/L	SM-254 D-97
B.O.D. (5-Day) - Percent Removal	96	% *	

TSS	Result	Units	Method
Influent	224.4	mg/L	SM-5210 B-01
Effluent	6.7	mg/L	SM-254 D-97
TSS - Percent Removal	97	% *	

\* Percent Removal = [(Average Influent - Average Effluent)/Average Influent] x 100%

The analysis of wastewater is conducted in accordance with US EPA approved methods listed in 40CFR Part 136. All results expressed on an as received basis unless indicated by a footnote.

These are the test results for your wastewater facility. You will want to keep these on file.

If you have any questions, please advise.

Natalie Frazier  
Lab Director