



Water Treat Technology

Certified Wastewater
Contract Operator
Consulting Services

16 Greve Drive, Centralia, IL 62801
Phone: (618) 923-0520 Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Robert Risley, IEPA Class 1
Wastewater Treatment Operator
Industrial Engineer B.S.

PERMIT NUMBER: MO-0132004
CLIENT: Oak Creek Estates Wastewater Treatment Facility
SAMPLE: Inf/Eff - Percent Removal
DATE: 6/10/2019
REPORTING MONTH: 2nd Qtr
SAMPLE DATE: 6/7/2019

| TSS | Result | Units | Limit | Method |
|-----------------------|--------|-------|-------|--------------|
| Influent | 417.0 | mg/L | | SM-5210 B-01 |
| Effluent | 11.6 | mg/L | | SM-254 D-97 |
| TSS - Percent Removal | 97 | % * | 85% | |

* Percent Removal = $[(\text{Average Influent} - \text{Average Effluent}) / \text{Average Influent}] \times 100\%$

The analysis of wastewater is conducted in accordance with US EPA approved methods listed in 40CFR Part 136. All results expressed on an as received basis unless indicated by a footnote.

These are the test results for your wastewater facility. You will want to keep these on file.

If you have any questions, please advise.

Natalie Frazier
Lab Director