



Water Treat Technology

Certified Wastewater
Contract Operator
Consulting Services

16 Greve Drive, Centralia, IL 62801
Phone: (618) 923-0520 Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Robert Risley, IEPA Class 1
Wastewater Treatment Operator
Industrial Engineer B.S.

PERMIT NUMBER: MO-0132004

CLIENT: Oak Creek Estates Wastewater Treatment Facility

SAMPLE: Inf/Eff - Percent Removal

DATE: 6/4/2019

REPORTING MONTH: 2nd Qtr

SAMPLE DATE: 5/29/2019

B.O.D. (5-Day)	Result	Units	Limit	Method
Influent	170.4	mg/L		SM-5210 B-01
Effluent	4.7	mg/L		SM-254 D-97
B.O.D. (5-Day) - Percent Removal	97	% *	85%	

TSS	Result	Units	Limit	Method
Influent	417.0	mg/L		SM-5210 B-01
Effluent	28.7	mg/L		SM-254 D-97
TSS - Percent Removal	93	% *	85%	

* Percent Removal = [(Average Influent - Average Effluent)/Average Influent] x 100%

The analysis of wastewater is conducted in accordance with US EPA approved methods listed in 40CFR Part 136. All results expressed on an as received basis unless indicated by a footnote.

These are the test results for your wastewater facility. You will want to keep these on file.

If you have any questions, please advise.

Natalie Frazier
Lab Director