



**CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES**

**16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com**

**Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.**

**FACILITY :** VILLAGE OF TAMAROA  
**DATE :** May 28, 2018  
**REPORTING MONTH :** May 2018

**DEAR SIR :**

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	Fecal Coli. (N/100ml)
5/7/18	INF	71.4	28.4	—	—	—	—
“	EFF	26.5	13.6	8.91	0.138	7.10	2400
							(May—Oct)
<b>Treasurer:</b>							

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC**

If there are any questions, please advise.  
Comments:

(V. TAM.)

( \* CBOD 5 if applicable )