



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

FACILITY : **VILLAGE OF WALTONVILLE**
DATE : **MARCH 28, 2018**
REPORTING MONTH : **MARCH 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA.

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	D.O. (PPM)	Fecal Coli. (N/100ml)	NH3-N (PPM)
3/20/18	INFLUENT	129	44	—	—	—	—
“	EFFLUENT	21	50	8.61	12.16	—	0.686

Complete DMR's using your flows and the above data and submit DMR's to the following address, or submit via the NetDMR system:

IEPA/BOW/CAS #19
P.O. Box 19276
Springfield, IL 62794-9276

If there are any questions, please advise.
Comments:

(V. Walt)

(* CBOD 5 if applicable)

Robert Risley — Lab Director