



Water Treat Technology

**CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES**

**16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979**

e-mail: rrisley@water-treat-tech.com

**Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.**

**FACILITY : VILLAGE OF WALTONVILLE
DATE : July 25, 2018
REPORTING MONTH : July 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA.

| DATE | SAMPLE POINT | * BOD 5 (PPM) | S. S. (PPM) | p H (UNITS) | D.O. (PPM) | Fecal Coli. (N/100ml) | NH3-N (PPM) |
|-------------|---------------------|----------------------|--------------------|--------------------|-------------------|------------------------------|--------------------|
| 07/05/18 | INFLUENT | 183.2 | 273.6 | — | — | — | — |
| “ | EFFLUENT | 26.7 | 44.7 | 9.21 | 4.85 | 0 | 0.783 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Complete DMR's using your flows and the above data and submit DMR's to the following address, or submit via the NetDMR system:

IEPA/BOW/CAS #19
P.O. Box 19276
Springfield, IL 62794-9276

If there are any questions, please advise.
Comments:

(V. Walt)

(* CBOD 5 if applicable)

Robert Risley — Lab Director