



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

e-mail: rrisley@water-treat-tech.com

FACILITY : CITY OF WAMAC
DATE : JANUARY 28, 2018
REPORTING MONTH : JANUARY 2018

DEAR SIR :

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D. O. (PPM)	Fecal Coli. (N/100ml)
1/14/18	INF.	120	102	—	—	—	—
“	EFF.	NO	FLOW				
							(May-Oct)
3 days	Lag. check						
NOTE :							

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.
Comments:

(Wamac)

(* CBOD 5 if applicable)