



Water Treat Technology

Robert Risley, IEPA Class 1 Certified
Wastewater Treatment Operator
& Industrial Engineer B.S.

16 Greve Drive, Centralia, IL 62801
Phone: (618) 923-0520 Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Contract Operator
&
Consulting Services

FACILITY: VILLAGE OF ALMA

DATE: 9/28/2018

REPORTING MONTH: September 2018

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.

| DATE | SAMPLE | * BOD5 (ppm) | TSS (ppm) | pH | NH ₃ -N (ppm) | DO (ppm) | Fecal Coli (N/100mL) |
|---------------|------------|-----------------|--------------|------|-----------------------------|-------------|-------------------------|
| 09/01/18 | INF | 219.00 | 8.00 | 0.00 | --- | --- | --- |
| 09/01/18 | EFF | 4.10 | 4.00 | 7.38 | 0.03 | 5.71 | 1,600 |
| | | | | | | | (May - Oct) |
| | | | | | | | |
| 3 Days | WWTP Check | | | | | | |
| Attn: Russell | | | | | | | |

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.

If you have any questions, please advise.

Robert Risley
Lab Director

* CBOD 5 if applicable