



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

FACILITY : **Village of ALMA**
DATE : **July 25, 2018**
REPORTING MONTH : **July 2018**

DEAR SIR :

Below is a summary of test results on your wastewater facility. **These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE | SAMPLE POINT | * BOD 5 (PPM) | S. S. (PPM) | p H | NH3-N (PPM) | D. O. (PPM) | Fecal Coli. (N/100 ml.) |
|---------------|--------------|---------------|-------------|------|-------------|-------------|-------------------------|
| 07/01/18 | INFLUENT | 127 | 53 | 7.59 | — | — | — |
| “ | EFFLUENT | 1.1 | 2.4 | 7.05 | 0.139 | 6.35 | 0 |
| | | | | | | | (May—Oct) |
| | | | | | | | |
| | | | | | | | |
| 3 days | WWTP check | | | | | | |
| | | | | | | | |
| Attn: Russell | | | | | | | |

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.

(ALMA)

(* CBOD 5 if applicable)

Comments: