

Water Treat Technology

Robert Risley, IEPA Class 1 Certified Wastewater Treatment Operator & Industrial Engineer B.S. 16 Greve Drive, Centralia, IL 62801
Phone: (618) 923-0520 Fax: (877) 349-2979
e-mail: rrisley@water-treat-tech.com

& Consulting Services

Contract Operator

FACILITY: ARCHWAY CAMPGROUND STP

DATE: 3/25/2019

REPORTING MONTH: March 2019

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.

| DATE | SAMPLE | * BOD5 (ppm) | TSS (ppm) | рН | NH ₃ -N (ppm) | DO (ppm) | Fecal Coli (N/100mL) | CL2 Resid. (ppm) |
|----------|--------|-----------------|--------------|------|-----------------------------|-------------|-------------------------|---------------------|
| 03/23/19 | INF | 21.80 | 176.00 | | | | | |
| 03/23/19 | EFF | 14.50 | 11.30 | 7.25 | 5.42 | 5.08 | • | - |
| | | | | | | | (May - Oct) | (May - Oct) |
| | | | | | | | | |
| | | | | | | | | |
| Ralph: | | | | | | | | |

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.

If you have any questions, please advise.

Natalie Frazier Lab Director

* CBOD 5 if applicable