



CERTIFIED WASTEWATER
CONTRACT OPERATOR
CONSULTING SERVICES

16 Greve Drive
Centralia, IL 62801
Phone: (618) 923-0520
Fax: (877) 349-2979

Robert Risley
IEPA CLASS 1
WASTEWATER TREATMENT OPERATOR
INDUSTRIAL ENGINEER B.S.

e-mail: rrisley@water-treat-tech.com

FACILITY : VILLAGE OF CENTRAL CITY
DATE : May 28, 2018
REPORTING MONTH : May 2018

DEAR SIR :

Below is a summary of test results on your wastewater facility. **These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	EFF. D.O.	Fecal Coli. (N/100 ml.)	LAGOON D.O. N-S-E-W (PPM)
5/3/18	INF-1	69	117	—	—	—	—	
“	EFF-1	0.60	31	8.91	0.063	5.32		
5/17/18	INF-2	114	88	—	—	—	—	
“	EFF-2	1.12	26	8.91	0.959	6.49		
5/3/18								8.51, 8.02, 8.60, 8.35
NOTE:								

Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC

If there are any questions, please advise.
Comments:

(C. City)

(* CBOD 5 if applicable)