



**CERTIFIED WASTEWATER  
CONTRACT OPERATOR  
CONSULTING SERVICES**

**16 Greve Drive  
Centralia, IL 62801  
Phone: (618) 923-0520  
Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com**

**Robert Risley  
IEPA CLASS 1  
WASTEWATER TREATMENT OPERATOR  
INDUSTRIAL ENGINEER B.S.**

**FACILITY : CROSSROADS MHP  
DATE : FEBRUARY 28, 2018  
REPORTING MONTH FEBRUARY 2018**

**DEAR SIR :**

Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. **Do not send this sheet to IEPA. See IEPA reporting information below.**

DATE	SAMPLE POINT	* BOD 5 (PPM)	S. S. (PPM)	p H (UNITS)	NH3-N (PPM)	D.O. (PPM)	Fecal Coliform (N/100 ml.)
2/10/18	INFLUENT	(200)	(175)	—	—	—	—
“	EFFLUENT	13.5	5.3	7.3	15.3	3.95	
							(May—Oct)
<b>NOTE:</b>							

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROInC**

**(X-Rd MHP)**

**( \* CBOD 5 if applicable )**