



# Water Treat Technology

Robert Risley, IEPA Class 1 Certified  
Wastewater Treatment Operator  
& Industrial Engineer B.S.

16 Greve Drive, Centralia, IL 62801  
Phone: (618) 923-0520 Fax: (877) 349-2979  
e-mail: rrisley@water-treat-tech.com

Contract Operator  
&  
Consulting Services

FACILITY: DUBOIS CTR CAMP

DATE: 12/21/2018

REPORTING MONTH: December 2018

**Below is a summary of test results on your wastewater facility. These results should be kept on file at your office. Do not send this sheet to IEPA. See IEPA reporting information below.**

| DATE     | SAMPLE | * BOD5<br>(ppm) | TSS<br>(ppm) | pH   | NH <sub>3</sub> -N<br>(ppm) | DO<br>(ppm) | Fecal Coli<br>(N/100mL) |
|----------|--------|-----------------|--------------|------|-----------------------------|-------------|-------------------------|
| 12/08/18 | INF    | 98.90           | 294.40       | ---  | ---                         | ---         | ---                     |
| 12/08/18 | EFF    | NO FLOW         | 0.00         | 0.00 | 0.00                        | 0.00        | 0                       |
|          |        |                 |              |      |                             |             | (May - Oct)             |
|          |        |                 |              |      |                             |             |                         |
|          |        |                 |              |      |                             |             |                         |
|          |        |                 |              |      |                             |             |                         |

**Using the NetDMR reporting system, I will electronically sign and submit your DMR reports to IEPA by the 25th of this following month... Robert Risley / ROINC.**

If you have any questions, please advise.

Robert Risley  
Lab Director

\* CBOD 5 if applicable